CRRC
COOL ROOF RATING COUNCIL

PRI

ASPHALT

TECHNOLOGIES

COOL ROOF RATING COUNCIL Accredited Independent Test Laboratory

COOL ROOF RATING COUNCIL TEST RESULTS REPORT

1. Name of CRRC Licensed Seller/OM Metacrylics	2. Contact Name Mark Anthenien
3. Company Address. 142 N. 27th Street San Jose, CA 95116-1118	4. Contact Address (if different from #3)
5. Email Address sales@metacrylics.com	6. Phone Voice 408-280-7733
7. CRRC License Seller/OM ID 0660	8. Phone Fax 408-280-6329
9. Product Name and Description Acrylic White Clear Stone Coat	10. Product Identification Code None
11. Laboratory ID : PRI	12. Laboratory Report ID MTA-001-02-01

13. Tested Radiative Properties

Batch A – Mfr. Batch # 9/10/02 (White) Batch A – Mfr. Batch # 8/19/02 (Clear)	Reflectance	Emittance	Batch B – Mfr. Batch # 9/24/02 (White) Batch B – Mfr. Batch # 9/13/02 (Clear)	Reflectance	Emittance
Panel 1	86.4	0.90	Panel 1	86.7	0.90
Panel 2	86.4	0.91	Panel 2	86.7	0.90
Panel 3	86.5	0.91	Panel 3	86.6	0.90
Average Batch Result	86.4	0.91	Average Batch Result	86.7	0.90

Coating System Description:
4 Gallons/100 ft.^{2} White Acrylic and 1/8 gallon 100 ft.^{2} Clear Stone Coat

14. Average for all tests: Solar Reflectance: 87 Thermal Emittance: 0.90

15. Tests conducted:

__	E 903 Test Report	Date:_____
__	E 408 Test Report	Date:_____
__	E 1918 Test Report	Date:_____
x	CRRC Test Report	Date: 10/28/02
x	C 1371 Test Report	Date: 10/28/02

16. I hereby attest that test values reported are true and accurate:

2/19/03

Donald C. Portfolio, Vice President — Date

MTA 001-02-01 PRI Accreditations: ICBO TL-189; NES Report No. NER-639; CRRC; Metro-Dade 01-0727.03

The test results, opinions, or interpretations are based on the material supplied by the client. This report is for the exclusive use of stated client. No reproduction or facsimile in any form can be made without the client's permission. This report shall not be reproduced except in full without the written approval of this laboratory. PRI Asphalt Technologies, Inc. assumes no responsibility nor makes a performance or warranty statement for this material or products and processes containing this material in connection with this report.