


COOL ROOF RATING COUNCIL NOTIFICATION OF PRODUCT RATING




	Notification Provided By: Cool Roof Rating Council 2435 N. Lombard St. Portland, OR 97217	Notification Provided To: Metacrylics 365 Obata Way, Gilroy, CA 95020
---	---	---

Product Brand:	Metacrylics	Product Type:	Coating
Product Model:	High Solids Silicone White	Initial SRI:	110
Company:	Metacrylics	3 Year SRI:	86
Contact Name:	Marc Rosenthal	Slope Types:	Low
Telephone:	9195982428	Color:	Bright White

		Initial	Weathered
	Solar Reflectance	0.87	0.70
	Thermal Emittance	0.89	0.90
	Rated Product ID	0660-0003	
	Licensed Manufacturer	0660	
Classification	Standard Product		
<p>Cool Roof Rating Council ratings are determined for a fixed set of conditions, and may not be appropriate for determining seasonal energy performance. The actual effect of solar reflectance and thermal emittance on building performance may vary.</p> <p>Manufacturer of product stipulates that these ratings were determined in accordance with the applicable Cool Roof Rating Council procedures.</p>			

The Cool Roof Rating Council (CRRC), an ISO 17065 accredited organization, has reviewed the test results data provided by a CRRC-approved ISO 17025 testing laboratory and has determined this roofing product meets the requirements described in the ANSI/CRRC S100 Standard and the CRRC-1 Program Manual. This Notification of Rating is subject to all terms and conditions of the Licensee Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

The Notification of Rating certificate for the approved initial ratings is valid until an updated certificate is issued by the CRRC that includes the approved three-year aged ratings. The certificate with the approved three-year aged ratings is valid until either the CRRC or Licensee removes the product from the CRRC Rated Products Directory.

			12/31/2017
Technical Reviewer	Application Reviewer	Management Approval	Date